




CXR Larus Corporation
 894 Faulstich Court
 San Jose, CA 95112-1361 USA

800-999-9946 or 408-573-2700

November 16, 2007

APPLICATIONS NOTE 114

StarClock TiemPo 6400 Main Chassis Unit Power Restrictions



~~~~~

~~~~~

A small population of StarClock TiemPo 6400A main chassis units has been produced with a restriction in the power input specification. The units will accept nominal 24 or 48 volt DC power, but the polarity must be negative. With this in mind, the negative power input is attached to the A or B power strips at PWR A or PWR B. The ground of the power (which may be power supply positive) is attached to GND A or GND B. Since the traditional power source in a telco central office or equipment room is -48VDC, this restriction should have limited impact.

The affected units are identified in this way:
Model 6400A
Issue 1 through 7

Otherwise, Issue 0 is not affected. Issue 8 and above is not affected.
